

E.W. Howell Co., LLC

113 Crossways Park Drive

Woodbury, NY 11797

Phone: 516-921-7100

Fax: 516-921-7920

REQUEST FOR INFORMATION

No. 00014

TITLE: Power Unit Coiling Doors

DATE: 8/27/2009

PROJECT: BNL CCWF-II

JOB:

TO: Attn: Allan Raphael
Brookhaven National Laboratory
Brookhaven Sciences Associates, LLC
Project Modernization Office
Upton, NY 11973-5000
Phone: 631-344-5854

STARTED:

COMPLETED:

REQUIRED: 9/3/2009

WORK

IMPACT: Unknown

SCHEDULE

IMPACT: Unknown

COST

IMPACT: Unknown

QUESTION:

August 27, 2009
Power Unit Coiling Doors

The specifications call out for a power unit to reduce the pull for operating the coiling doors. The power units are not indicated on the electrical power plan or the panel schedule. Please indicate panel feeds and wiring.

CC:File

PROPOSED SOLUTION:

ANSWER:

ALL DOORS ARE MANUALLY OPERATED.

~~UPGRADE TO MOTOR ASSIST ONLY AT DIRECTION OF CLIENT.~~

Not required
A. R. Hill
9/21/09



Requested By: E.W. Howell Co., LLC

Signed: _____

Lauren Bergin

Date: _____

9/12/09